

Certificate of Compliance

Certificate:	70054038	Master Contract:	164129 (112439_0_000)
Project:	70198711	Date Issued:	2019-02-25
Issued to:	Bonomi Industries S.r.l. (formerly Ru Via Padana Superiore 29 Mazzano, Brescia 25080 ITALY Attention: John Shelander	ubinetterie Utensile	rie Bonomi)

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Nick Shrewsbury-Gee Nick Shrewsbury-Gee, P.Eng

PRODUCTS

CLASS 3371-12 – VALVES (GAS) Manually Operated For Use on Piping CLASS 3371-92 – VALVES (GAS) Manually Operated For Use in House Piping Systems-Certified to U.S. Standards CLASS 3371-14 – VALVES (GAS) Manually Operated Metallic for Use in Piping Systems CLASS 3371-94 – VALVES (GAS) Manually Operated Metallic for Use in Piping Systems-Certified to U.S. Standards CLASS 3371-10 – VALVES (GAS) Lever Operated Non-Lubricated Shutoff CLASS 3371-08 – VALVES (GAS) General Use CLASS 3371-88 – VALVES (GAS) General Use – Certified to U.S. Standards.

3371-12 - VALVES (GAS) Manually Operated For Use on Piping 3371-92- VALVES (GAS) Manually Operated For Use in House Piping Systems-Certified to U.S. Standards

Trade Name: RUB

Gas Ball Valves

S.92, S.95, S.88, Rated Pressure 5 psig, Inlet Size 1/4"
S.92, S.95, S.88, Rated Pressure 5 psig, Inlet Size 3/8"
S.92, S.95, S.88, S.82, Rated Inlet Pressure 5 psig, Inlet Size 1/2"
S.92, S.95, S.80, S.88, S.82, S80E43A, S80E43BS, S80E43BP, Rated Inlet Pressure 5 psig, Inlet Size 3/4"
S.92, S.95, S.80, S.88, S.82, S80F43A, S80F43BL, Rated Inlet Pressure 5 psig, Inlet Size 1"
S.92, S.95, S.88, S.82, S80G43A, Rated Inlet Pressure 5 psig, Inlet Size 1-1/4"
S.92, S.95, S.88, S.82, S80H43A, Rated Inlet Pressure 5 psig, Inlet Size 1-1/4"



 Certificate:
 70054038

 Project:
 70198711

Gas Ball Valves

Master Contract: 164129 Date Issued: 2019-02-25

S.92, S.95, S.88, S.82, S80I43A, Rated Inlet Pressure 5 psig, Inlet Size 2"

S.80, Rated Inlet Pressure 5 psig, Inlet Size 3/4"M

S.80, Rated Inlet Pressure 5 psig, Inlet Size I" M

S.80, Rated Inlet Pressure 5 psig, Inlet Size 1- ¹/₄" M

S.80, Rated Inlet Pressure 5 psig, Inlet Size 1- $\frac{1}{2}$ "M

S.80, Rated Inlet Pressure 5 psig, Inlet Size 2" M

3371-10- VALVES (GAS) Lever Operated Non-Lubricated Shutoff For Use With Natural and Propane Gas

Trade Name: RUB

S.92, S.95, Rated Pressure 125 psig, Inlet Size ¼"
S.92, S.95, Rated Pressure 125 psig, Inlet Size 3/8"
S.92, S.95, Rated Pressure 125 psig, Inlet Size ½"
S80E43BS, S80E43BP, Rated Pressure 125 psig, Inlet Size ¾"
S80F43BL, Rated Pressure 125 psig, Inlet Size 1"
S.92, S.95, S.80, S.80G43, Rated Pressure 125 psig, Inlet Size 1- ¼"
S.92, S.95, S.80, S.80H43, Rated Pressure 125 psig, Inlet Size 1- ½"
S.92, S.95, S.80, S.80I43, Rated Pressure 125 psig, Inlet Size 1- ½"
S.92, S.95, S.80, S.80I43, Rated Pressure 125 psig, Inlet Size 2″
S.92, S.95, S.80, S.88, S80E43, Rated Pressure 125 psig, Inlet Size 3/4" M

S.92, S.95, S.80, S.88, S80F43, Rated Pressure 125 psig, Inlet Size I" M



 Certificate:
 70054038

 Project:
 70198711

Master Contract: 164129 Date Issued: 2019-02-25

3371-14 - VALVES (GAS) Manually Operated Metallic for Use in Piping Systems For Use With Natural and Propane Gas

Trade Name: RUB

S.80, S80E43BS, S80E43BP Rated Pressure 125 psig, Inlet Size ³/₄" S.80, S.92, S.95, S80F43BL Rated Pressure 125 psig, Inlet Size 1" S.95 Rated Pressure 125 psig, Inlet Size 1- ¹/₄" S.95 Rated Pressure 125 psig, Inlet Size 1- ¹/₂" S.95 Rated Pressure 125 psig, Inlet Size 2"

3371-94- VALVES (GAS) Manually Operated Metallic for Use in Piping Systems-Certified to U.S. Standards

For Use With Natural, Mfd., Mixed, Liquefied Petroleum Gases and LP Gas-Air Mixtures

Trade Name: RUB

Straight Gas Valve (Ball Type) S.95, Rated Pressure 125 psig, Inlet Size 1/4" S.95, Rated Pressure 125 psig, Inlet Size 3/8" S.95, Rated Pressure 125 psig, Inlet Size 1/2" S.95, S.80, S.80G43, Rated Pressure 125 psig, Inlet Size 1-1/4" S.95, S.80, S.80H43, Rated Pressure 125 psig, Inlet Size 1-1/2" S.95, S.80, S.80 I43, Rated Pressure 125 psig, Inlet Size 2" S.92, S.95, S.80, S.88, S80E43, S80E43BS, S80E43BP, Rated Pressure 125 psig, Inlet Size 3/4"M S.92, S.95, S.80, S.88, S80F43, S80F43BL Rated Pressure 125 psig, Inlet Size 1"M

For operation at ambient temperatures of -20°F to 150°F (-29°C to 66°C) and 125 psig.

3371-08 - VALVES (GAS) General Use

For Use With Natural, Mfd., Mixed, Liquefied Petroleum Gases and LP Gas-Air Mixtures

Trade Name: RUB

Straight Gas Ball Valve S.92*, S.95*, S.88*, Inlet Size 1/4" S.92*, S.95*, S.88*, Inlet Size 3/8" S.92*, S.95*, S.88*, S. 82*, Inlet Size 1/2" S.92*, S.95*, S.88*, S. 82*, Inlet Size 3/4" S.92*, S.95*, S.88*, S.82*, Inlet Size 1"

For use on commercial cooking equipment. *For operation at ambient temperatures of -40°F to 350°F, ½ psig.



 Certificate:
 70054038

 Project:
 70198711

Master Contract: 164129 Date Issued: 2019-02-25

3371-88 - VALVES (GAS) General Use - Certified to U.S. Standards For Use With Natural, Mfd., Mixed, Liquefied Petroleum Gases and LP Gas-Air Mixtures

Trade Name: RUB

<u>Straight Ball Valve</u> S.92*, S.95*, S.88*, Inlet Size 1/4" S.92*, S.95*, S.88*, Inlet Size 3/8" S.92*, S.95*, S.88*, S. 82*, Inlet Size 1/2" S.92*, S.95*, S.88*, S. 82*, Inlet Size 3/4" S.92*, S.95*, S.88*, S.82*, Inlet Size 1"

For use on commercial cooking equipment. *For operation at ambient temperatures of -40"F to 350°F, ½ psig.

APPLICABLE REQUIREMENTS

ANSI Z21.15-2009·CSA 9.1-2009 ANSI Z21.15a-2012·CSA 9.1a-2012 ANSI Z21.15b-2013·CSA 9.1b-2013 - Manually Operated Gas Valves for Appliances, Appliance Connector Valves and Hose End Valves

ANSI/ASME B 16.44-2012 - Manually Operated Metallic Gas Valves For use In Aboveground Piping Systems Up To 5psi

ANSI/ASME B 16.33-2012 - Manually Operated Metallic Gas Valves For Use In Gas Piping Systems Up To 125 Psig

Certification Requirement CR91-002, for Manually Operated Gas Valves for Use on Piping Installed Indoors CSA 3.16-2015 - Lever Operated Non-Lubricated Gas Shut-Off Valves C.L.I.R. No. 35 June 12, 1989 - Manually Operated Gas (Appliance Shut-off Valves)

MARKINGS

Full marking details can be found in the descriptive report



Supplement to Certificate of Compliance

Certificate: 70054038

Master Contract: 164129 (112439_0_000)

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

		Troduct Certification Instory
Project	Date	Description
70198711	2019-02-25	Add S.80 SurePass ball valves to certificate 70054038
70190846	2018-07-27	Change OT58 – obsolete to CW617N –updated Nomenclature change to same material.
70054038	2016-01-18	Supersedes Report No. 1381270. Correct temperature range for models listed under Class 3371-94 and update trademark in markings.

Product Certification History